



Ref. Certif. No.

SE-106823

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant

Shanghai Ebasee Electric Co., Ltd.
No.18 Gutang Road, Pudong, Shanghai 201206,
CHINA

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

Un= 240/415V~(1P), 240V~(1P+N), 415V~(2P, 3P, 3P+N, 4P)
In= 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A
B-, C- & D- Type, Ics= Icn= 6000A
50/60Hz, Ui= 500V, Uimp= 4kV

Trademark (if any)

EBASEE

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

EBS6BN

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

211102232SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Signature: *Quan Li*

Date: 07 January, 2022

Quan Li